



**Illuminating**  
ENGINEERING SOCIETY



**JOINT IDA - IES**

**MODEL**

**LIGHTING**

**ORDINANCE**

**(MLO)**

**with USER'S GUIDE**

**June 15, 2011**

## The User Notes

The User Notes are intended to clarify the sections of the MLO for the various audiences who will use it: lighting designers, city officials, engineers, citizen groups, and others. Every effort has been made to keep the language technically accurate and clear, but since different disciplines may use the same term in different ways, or have different interpretations, some guidance may be helpful. While these Notes can not be a full tutorial on modern lighting design, it is hoped that the Notes will help facilitate the dialogue necessary to adopt the MLO.

## Background

The problems of light pollution first became an issue in the 1970s when astronomers identified the degradation of the night sky due to the increase in lighting associated with development and growth. As more impacts to the environment by lighting have been identified, an international “dark sky” movement is advocating for the precautionary approach to outdoor lighting design.

Many communities have passed anti-light-pollution laws and ordinances. However, there is little or no agreement among these laws, and they vary considerably in language, technical quality, and stringency. This is confusing for designers, engineers, and code officials. The lack of a common basis prevents the development of standards, educational programs, and other means of achieving the goal of effective lighting control.

This MLO will allow communities to drastically reduce light pollution and glare and lower excessive light levels. The recommended practices of the IES can be met using readily available, reasonably priced lighting equipment. However, many conventional lighting practices will no longer be permitted, or will require special permits.

This Model Lighting Ordinance (MLO) is the result of extensive efforts by the International Dark Sky Association (IDA) and the Illuminating

Engineering Society of North America (IES). Among its features is the use of lighting zones (LZ0-4) which allow each governing body to vary the stringency of lighting restrictions according to the sensitivity of the area as well as accommodating community intent. In this way, communities can fine-tune the impact of the MLO without having to customize the MLO. The MLO also incorporates the Backlight-Uplight-Glare (BUG) rating system for luminaires, which provides more effective control of unwanted light.

Joint IDA-IESNA  
Model Outdoor Lighting  
Ordinance (MLO)

June 15, 2011

## CONTENTS

- I. Preamble.....5
- II. Lighting Zones.....5
- III. General Requirements for All Outdoor Lighting.....8
- IV. Requirements for Non-Residential Outdoor Lighting.....11
- V. Requirements for Residential Outdoor Lighting.....19
- VI. Lighting by Special Permit Only.....20
- VII. Existing Lighting.....21
- VIII. Enforcement and Penalties (Reserved).....22
- IX. Tables.....23
- X. Definitions.....32
- XI. (Optional) Street Lighting Ordinance.....38

**General Notes in Adopting this Model Ordinance**

Adoption of this ordinance should follow the established development, review, and approval processes of the adopting authority. If no such processes are in place, this ordinance may be adopted as a new independent section of the Municipal Code.

The MLO is probably best adopted as an “overlay zoning” ordinance. This means that it overlays, but is different from, land-use zoning. It can be added to or integrated into existing ordinances or codes and cross-referenced to other applicable codes and ordinances such as the electrical code, the sign code, planning ordinances, etc.

The MLO may best be managed by assigning it to planning officials and using existing administrative structures.

Because of the diverse community and lighting needs across large areas, this MLO is not intended for adoption as a state, provincial or national ordinance. Regional coordination is encouraged. Light pollution knows no boundaries, and the effects of polluting light persist as far as 200 kilometers (about 120 miles) from the source. One large city could adopt the MLO and dramatically affect a region, but adoption in suburbs and small towns must be part of a regional effort to achieve significant improvements in the overall quality of the night sky.

Adopting agencies should also consider that the MLO, like all other modern codes, is designed to evolve over time. Lighting technology will change, and MLO changes will be needed every few years. On-going renewal cycles are strongly recommended as any part of an adopting ordinance.

**MLO Development and Task Force Members**

This Model Lighting Ordinance has been developed as a joint undertaking by the Illuminating Engineering Society and the International Dark-Sky Association.

The Joint Task Force responsible for developing the MLO include

IDA  
 Co-Chair: Jim Benya  
 Co-Chair: Nancy Clanton  
 Leslie Lipstein  
 Leo Smith  
 Michael Mutmansky

IES  
 Naomi Miller  
 Cheryl English  
 Denis Lavoie  
 Eric Gibson

John Walter representing the electric utility industry also contributed as a member of the Joint Task Force.

The MLO received input and comments from many individuals and organizations through the public review process, and these are responsible for shaping and refining the document. Specific thanks are due to the Lighting Research Center for their input, especially since much of the Performance Method was derived from or informed by the LRC's “Outdoor Site-lighting Performance (OSP) Model”. Australia 's AS 4284-1997 “Control of the obtrusive effects of outdoor lighting” was also helpful for improving this model.

**I. PREAMBLE - User's Guide**

In general, the preamble is part of the ordinance but is typically not part of the code. It establishes the reasons why the municipality is undertaking these regulations.

Local governments may add other purposes to the Preamble including established local government environmental or energy goals that support the model lighting ordinance. The environmental impacts of outdoor lighting fall into two categories: carbon footprint (energy used in the life of a lighting product) and obtrusive light.

CARBON FOOTPRINT	OBTRUSIVE LIGHT
Cost & Impact of Mining the Materials Used	Impact on Humans
Energy Used in Production	Impact on the Environment
Energy Used during Product Life	
Disposal/Recycling Costs	

**II. LIGHTING ZONES - User's Guide**

Lighting zones reflect the base (or ambient) light levels desired by a community. The use of lighting zones (LZ) was originally developed by the International Commission on Illumination (CIE) and appeared first in the US in IES Recommended Practice for Exterior Environmental Lighting, RP-33-99.

It is recommended that lower lighting zone(s) be given preference when establishing zoning criteria. Selection of lighting zone or zones should be based not on existing conditions but rather on the type of lighting environments the jurisdiction seeks to achieve. For instance, new development on previously rural or undeveloped land may be zoned as LZ-1. Using lighting zones allows a great deal of flexibility and customization without the burden of excessive regulation. For example, a jurisdiction may choose to establish vertical lighting zones with the lighting zone at street level at a higher zone than the residential housing on upper levels.

**I. PREAMBLE - Ordinance Text**

The purpose of this Ordinance is to provide regulations for outdoor lighting that will:

- a. Permit the use of outdoor lighting that does not exceed the minimum levels specified in IES recommended practices for night-time safety, utility, security, productivity, enjoyment, and commerce.
- b. Minimize adverse offsite impacts of lighting such as light trespass, and obtrusive light.
- c. Curtail light pollution, reduce skyglow and improve the nighttime environment for astronomy.
- d. Help protect the natural environment from the adverse effects of night lighting from gas or electric sources.
- e. Conserve energy and resources to the greatest extent possible.

**II. LIGHTING ZONES - Ordinance Text**

The Lighting Zone shall determine the limitations for lighting as specified in this ordinance. The Lighting Zones shall be as follows:

**LZ0: No ambient lighting**

Areas where the natural environment will be seriously and adversely affected by lighting. Impacts include disturbing the biological cycles of flora and fauna and/or detracting from human enjoyment and appreciation of the natural environment. Human activity is subordinate in importance to nature. The vision of human residents and users is adapted to the darkness, and they expect to see little or no lighting. When not needed, lighting should be extinguished.

**II. LIGHTING ZONES (cont.) - User's Guide**

However, if an adjacent use could be adversely impacted by allowable lighting, the adopting authority may require that a particular site meet the requirements for a lower lighting zone. For example, the authority could specify Lighting Zone 1 or 2 requirements if a commercial development were adjacent to a residence, hospital or open space, or to any land assigned to a lower zone.

Lighting zones are best implemented as an overlay to the established zoning especially in communities where a variety of zone districts exists within a defined area or along an arterial street. Where zone districts are cohesive, it may be possible to assign lighting zones to established land use zoning. It is recommended that the lighting zone includes churches, schools, parks, and other uses embedded within residential communities.

Zone	Recommended Uses or Areas	Zoning Considerations
LZ-0	Lighting Zone 0 should be applied to areas in which permanent lighting is not expected and when used, is limited in the amount of lighting and the period of operation. LZ-0 typically includes undeveloped areas of open space, wilderness parks and preserves, areas near astronomical observatories, or any other area where the protection of a dark environment is critical. Special review should be required for any permanent lighting in this zone. Some rural communities may choose to adopt LZ-0 for residential areas.	Recommended default zone for wilderness areas, parks and preserves, and undeveloped rural areas.  Includes protected wildlife areas and corridors.
LZ-1	Lighting Zone 1 pertains to areas that desire low ambient lighting levels. These typically include single and two family residential communities, rural town centers, business parks, and other commercial or industrial/storage areas typically with limited nighttime activity. May also include the developed areas in parks and other natural settings.	Recommended default zone for rural and low density residential areas.  Includes residential single or two family; agricultural zone districts; rural residential zone districts; business parks; open space include preserves in developed areas.

**II. LIGHTING ZONES (cont.) - Ordinance Text**

**LZ1: Low ambient lighting**

Areas where lighting might adversely affect flora and fauna or disturb the character of the area. The vision of human residents and users is adapted to low light levels. Lighting may be used for safety and convenience but it is not necessarily uniform or continuous. After curfew, most lighting should be extinguished or reduced as activity levels decline.

**LZ2: Moderate ambient lighting**

Areas of human activity where the vision of human residents and users is adapted to moderate light levels. Lighting may typically be used for safety and convenience but it is not necessarily uniform or continuous. After curfew, lighting may be extinguished or reduced as activity levels decline.

**LZ3: Moderately high ambient lighting**

Areas of human activity where the vision of human residents and users is adapted to moderately high light levels. Lighting is generally desired for safety, security and/or convenience and it is often uniform and/or continuous. After curfew, lighting may be extinguished or reduced in most areas as activity levels decline.

**LZ4: High ambient lighting**

Areas of human activity where the vision of human residents and users is adapted to high light levels. Lighting is generally considered necessary for safety, security and/or convenience and it is mostly uniform and/or continuous. After curfew, lighting may be extinguished or reduced in some areas as activity levels decline.

**II. LIGHTING ZONES (cont.) - User's Guide**

Zone	Recommended Uses or Areas	Zoning Considerations
<b>LZ-2</b>	Lighting Zone 2 pertains to areas with moderate ambient lighting levels. These typically include multifamily residential uses, institutional residential uses, schools, churches, hospitals, hotels/motels, commercial and/or businesses areas with evening activities embedded in predominately residential areas, neighborhood serving recreational and playing fields and/or mixed use development with a predominance of residential uses. Can be used to accommodate a district of outdoor sales or industry in an area otherwise zoned LZ-1.	<p><b>Recommended default zone for light commercial business districts and high density or mixed use residential districts.</b></p> <p>Includes neighborhood business districts; churches, schools and neighborhood recreation facilities; and light industrial zoning with modest nighttime uses or lighting requirements.</p>
<b>LZ-3</b>	Lighting Zone 3 pertains to areas with moderately high lighting levels. These typically include commercial corridors, high intensity suburban commercial areas, town centers, mixed use areas, industrial uses and shipping and rail yards with high night time activity, high use recreational and playing fields, regional shopping malls, car dealerships, gas stations, and other nighttime active exterior retail areas.	<p><b>Recommended default zone for large cities' business district.</b></p> <p>Includes business zone districts; commercial mixed use; and heavy industrial and/or manufacturing zone districts.</p>
<b>LZ-4</b>	Lighting zone 4 pertains to areas of very high ambient lighting levels. LZ-4 should only be used for special cases and is not appropriate for most cities. LZ-4 may be used for extremely unusual installations such as high density entertainment districts, and heavy industrial uses.	<p><b>Not a default zone.</b></p> <p>Includes high intensity business or industrial zone districts.</p>

### III. GENERAL REQUIREMENTS - User's Guide

This Section sets out the requirements that apply to all lighting, both residential and non-residential.

Each adopting jurisdiction should incorporate their existing standards as to when compliance with new regulations is required, when repair or remodeling triggers compliance and if the new ordinance will be retroactive to existing development. The Applicability section of this model ordinance should serve as a guide if the adopting jurisdiction does not have standards or policies in place. Likewise, the adopting jurisdiction should use their existing policies and definitions of what constitutes public monuments, and temporary and/or emergency lighting. Community attitudes and precedents should be taken into account in deciding to regulate seasonal holiday lighting.

#### EXEMPTIONS - User's Guide

This is standard language intended to prevent conflict of laws and to give the community the ability to set specific lighting requirements in special plans and under use permits. It can be amended to conform to similar language in other ordinances. For example, while public monuments, statuary, and flags should be lighted, the lighting also should be limited to avoid excess.

Lighting for streets, roads, and highways is usually regulated by a street lighting ordinance, and is not covered by this model ordinance. However, since street lighting can affect nearby areas, some recognition of its effect is appropriate. (See Section XI)

#### SIGN LIGHTING - User's Guide

A sign lighting ordinance is strongly recommended if not already in place. It should carefully limit lighting to prevent over-lighted signs from being used to circumvent lighting ordinances.

### III. GENERAL REQUIREMENTS - Ordinance Text

#### A. *Conformance with All Applicable Codes*

All outdoor lighting shall be installed in conformance with the provisions of this Ordinance, applicable Electrical and Energy Codes, and applicable sections of the Building Code.

#### B. *Applicability*

Except as described below, all outdoor lighting installed after the date of effect of this Ordinance shall comply with these requirements. This includes, but is not limited to, new lighting, replacement lighting, or any other lighting whether attached to structures, poles, the earth, or any other location, including lighting installed by any third party.

***Exemptions from III.(B.)*** The following are not regulated by this Ordinance

- a. Lighting within public right-of-way or easement for the principal purpose of illuminating streets or roads. No exemption shall apply to any lighting within the public right of way or easement when the purpose of the luminaire is to illuminate areas outside the public right of way or easement, unless regulated with a streetlighting ordinance.

***Note to adopting agency: if using the street lighting ordinance (Section XI), this exemption should read as follows:***

Lighting within the public right-of-way or easement for the principal purpose of illuminating roads and highways. No exemption shall apply to any street lighting and to any lighting within the public right of way or easement when the purpose of the luminaire is to illuminate areas outside of the public right of way or easement.

- b. Lighting for public monuments and statuary.
- c. Lighting solely for signs (lighting for signs is regulated by the Sign Ordinance).
- d. Repairs to existing luminaires not exceeding 25% of total installed luminaires.

**III. GENERAL REQUIREMENTS (cont.) - Ordinance Text**

- e. Temporary lighting for theatrical, television, performance areas and construction sites;
- f. Underwater lighting in swimming pools and other water features
- g. Temporary lighting and seasonal lighting provided that individual lamps are less than 10 watts and 70 lumens.
- h. Lighting that is only used under emergency conditions.
- i. In lighting zones 2, 3 and 4, low voltage landscape lighting controlled by an automatic device that is set to turn the lights off at one hour after the site is closed to the public or at a time established by the authority.

**Exceptions to III. (B.)** All lighting shall follow provisions in this ordinance; however, any special requirements for lighting listed in a) and b) below shall take precedence.

- a. Lighting specified or identified in a specific use permit.
- b. Lighting required by federal, state, territorial, commonwealth or provincial laws or regulations.

**C. Lighting Control Requirements**

- 1. Automatic Switching Requirements  
Controls shall be provided that automatically extinguish all outdoor lighting when sufficient daylight is available using a control device or system such as a photoelectric switch, astronomic time switch or equivalent functions from a program-mable lighting controller, building automation system or lighting energy management system, all with battery or similar backup power or device.

**LIGHTING CONTROLS - User's Guide**

This section requires all outdoor lighting to have lighting controls that prohibit operation when sufficient daylight is available, and to include the capability, either through circuiting, dimming or alternating sources, to be able to reduce lighting without necessarily turning all lighting off.

**III. GENERAL REQUIREMENTS (cont.) - Ordinance Text**

**CURFEW REQUIREMENTS - User's Guide**

The intent is to reduce or eliminate lighting after a given time. Benefits include reduced environmental impact, longer hours of improved astronomy, energy savings, and improved sleeping conditions for residents. Additionally, some police departments have indicated that post-curfew light reductions make drive-by patrolling easier because it allows them to see further into and through a site.

The authority should determine the time of curfew and the amount of lighting reduction based on the character, norms and values of the community.

Typically, curfews go into effect one hour after the close of business. Restaurants, bars and major entertainment facilities such as sports stadiums, may require the curfew go into effect two hours after the close of business. The authority may elect to have no curfew for facilities with shift workers and 24 hour operations, or to extend the curfew time to meet specific needs. The MLO can be modified to address those concerns.

Areas without street lights or with very low ambient light levels should consider turning off all non-emergency lighting at curfew while commercial areas or urban areas may prefer a reduction in lighting levels. A reduction of at least 30% is recommended for most uses.

*Exceptions to III.(C.) 1.* Automatic lighting controls are not required for the following:

- a. Lighting under canopies.
- b. Lighting for tunnels, parking garages, garage entrances, and similar conditions.

2. Automatic Lighting Reduction Requirements  
The Authority shall establish curfew time(s) after which total outdoor lighting lumens shall be reduced by at least 30% or extinguished.

*Exceptions to III.(C.) 2.* Lighting reductions are not required for any of the following:

- a. With the exception of landscape lighting, lighting for residential properties including multiple residential properties not having common areas.
- b. When the outdoor lighting consists of only one luminaire.
- c. Code required lighting for steps, stairs, walkways, and building entrances.
- d. When in the opinion of the Authority, lighting levels must be maintained.
- e. Motion activated lighting.
- f. Lighting governed by special use permit in which times of operation are specifically identified.
- g. Businesses that operate on a 24 hour basis.

#### IV. NON-RESIDENTIAL LIGHTING - User's Guide

This section addresses non-residential lighting and multiple-family residences having common spaces, such as lobbies, interior corridors or parking. Its intent is to:

- Limit the amount of light that can be used
- Minimize glare by controlling the amount of light that tends to create glare
- Minimize sky glow by controlling the amount of uplight
- Minimize the amount of off-site impacts or light trespass

This MLO provides two methods for determining compliance. The *prescriptive method* contains precise and easily verifiable requirements for luminaire light output and fixture design that limit glare, uplight, light trespass and the amount of light that can be used. The *performance method* allows greater flexibility and creativity in meeting the intent of the ordinance. Note that both the prescriptive and the performance method limit the *amount* of light that can be used, but do not control *how* the lighting is to be used.

Most outdoor lighting projects that do not involve a lighting professional will use the prescriptive method, because it is simple and does not require engineering expertise.

For the prescriptive method, the initial luminaire lumen allowances defined in Table A (Parking Space Method) or B (Hardscape Area Method) will provide basic lighting (parking lot and lighting at doors and/or sensitive security areas) that is consistent with the selected lighting zone. The prescriptive method is intended to provide a safe lighting environment while reducing sky glow and other adverse offsite impacts. The Per Parking Space Method is applicable in small rural towns and is a simple method for small retail “mom and pop” operations without drive lane access and where the parking lot is immediately adjacent to the road. A jurisdiction may

#### IV. NON-RESIDENTIAL LIGHTING - Ordinance Text

For all non-residential properties, and for multiple residential properties of seven domiciles or more and having common outdoor areas, all outdoor lighting shall comply either with Part A or Part B of this section.

**PRESCRIPTIVE METHOD - User's Guide**

also allow a prescriptive method for classes of sites, such as car dealerships, gas stations, or other common use areas.

Note that the values are for initial luminaire lumens, not footcandles on the target (parking lot, sidewalk, etc). Variables such as the efficiency of the luminaire, dispersion, and lamp wear can affect the actual amount of light so the lumens per square foot allowance is not equal to footcandles on the site. By specifying initial luminaire lumen values, it is easier for officials to verify that the requirement is being met. Initial luminaire lumens are available from photometric data. Each initial luminaire lumens calculation should be supplied on the submittal form.

Solid state luminaires, such as LEDs, do not have initial lamp lumens, only initial luminaire lumens (absolute photometry). Other luminaires tested with relative photometry will have initial luminaire lumens which can be calculated by multiplying initial lamp lumens by the luminaire efficiency. In this example, three types of luminaires are used to light a parking area and building entry in a light commercial area. Two of these three luminaires use metal halide lamps: 70 watt wall mounted area lights and 150 watt pole mounted area lights. For these, the Initial Luminaire Lumens is equal to the initial lamp lumens multiplied by the luminaire efficiency. These values are entered into the compliance chart. The lumen value for the building mounted LED luminaires is equal to the lumens exiting the luminaire. Therefore, the value already represents the Initial Luminaire Lumens and no luminaire efficiency is needed. The total Luminaire Lumens for the site is equal to 247,840.

The allowable lumens are based on the lighting zone and the total hardscape area. Referencing Table B, the allowed lumens are 2.5/SF for LZ2. Multiplying this by the total hardscape square footage gives a value of 250,000 lumens allowed. Because this value is greater than the value calculated for the site, the project complies. Listed below is an example on a typical compliance worksheet for the Prescriptive Method.

**IV. NON-RESIDENTIAL LIGHTING (cont.) - Ordinance Text*****A. Prescriptive Method***

An outdoor lighting installation complies with this section if it meets the requirements of subsections 1, 2 and 3, below.

**1. Total Site Lumen Limit**

The total installed initial luminaire lumens of all outdoor lighting shall not exceed the total site lumen limit. The total site lumen limit shall be determined using either the Parking Space Method (Table A) or the Hardscape Area Method (Table B). Only one method shall be used per permit application, and for sites with existing lighting, existing lighting shall be included in the calculation of total installed lumens.

The total installed initial luminaire lumens is calculated as the sum of the initial luminaire lumens for all luminaires.

**IV. NON-RESIDENTIAL LIGHTING (cont.) - User's Guide**

**IV. NON-RESIDENTIAL LIGHTING (cont.) - Ordinance Text**

The allowable lumens are based on the lighting zone and the total hardscape area. Referencing Table B, the allowed lumens are 2.5/SF for LZ2. Multiplying this by the total hardscape square footage gives a value of 250,000 lumens allowed. Because this value is greater than the value calculated for the site, the project complies.

<b>PRESCRIPTIVE METHOD EXAMPLE - COMPLIANCE CHART</b>			
<i>Lamp Descriptions</i>	<i>QTY</i>	<i>Initial Luminaire Lumens</i>	<i>Total</i>
70 W Metal Halide	8	3,920	31,360
150 W Metal Halide	20	9,600	192,000
18 W LED	24	1,020	24,480
<b>TOTAL INITIAL LUMINAIRE LUMENS</b>			<b>247,840</b>
<b>SITE ALLOWED TOTAL INITIAL LUMENS*</b>			<b>250,000</b>
<b>PROJECT IS COMPLIANT?</b>			<b>YES</b>

\* Listed below is the method of determining the allowed total initial lumen for non-residential outdoor lighting using the hardscape areamethod. (Table B).

<b>SITE ALLOWED TOTAL INITIAL LUMENS</b>	
<i>Site Description</i>	Light Commercial
<i>Lighting Zone</i>	LZ-2
<i>Hardscape Area (SF)</i>	100,000
<i>Allowed Lumens per SF of Hardscape (Table B)</i>	2.5
<i>Site Allowed Total Initial Lumens (lumens per SF X hardscape area)</i>	250,000

**PRESCRIPTIVE METHOD (cont.) - User's Guide**

**IV. NON-RESIDENTIAL LIGHTING (cont.) - Ordinance Text**

**LIMITS TO OFFSITE IMPACTS**

**PRESCRIPTIVE METHOD**

The prescriptive method of the MLO restricts uplighting, including upward light emitted by decorative luminaires. A jurisdiction may choose to preserve some types of lighting, including lighting of monuments or historic structures. In this case, the adopting jurisdiction should exempt or otherwise regulate these types of lighting carefully so that it does not inadvertently allow glaring or offensive lighting systems.

Offsite effects of light pollution include glare, light trespass, sky glow, and impacts on the nocturnal environment . All of these are functions of the fixture or luminaire design and installation. This document replaces the previous luminaire classification terminology of full cut-off, semi cut-off, and cut-off because those classifications were not as effective in controlling offsite impacts as with the new IESNA luminaire classification system as described in TM-15-11.

A traditional method of defining light trespass is to identify a maximum light level at or near the property line. However, this method does not address offensive light that is not directed toward the ground, or the intensity of glaring light shining into adjacent windows. The requirements defined in Table C limit the amount of light in all quadrants that is directed toward or above the property line. The Backlight/Uplight/ Glare (BUG) rating will help limit both light trespass and glare. (A detailed explanation of the BUG system is provided in the section on Table C.)

The limits for light distribution established in Table C (for the BUG rating system) prevent or severely limit all direct upward light. A small amount of uplight reflected by snow, light-colored pavement or a luminaire's supporting arms is inevitable and is not limited by the prescriptive method of this ordinance.

2. Limits to Off Site Impacts

All luminaires shall be rated and installed according to Table C.

3. Light Shielding for Parking Lot Illumination

All parking lot lighting shall have no light emitted above 90 degrees.

Exception:


a) Ornamental parking lighting shall be permitted by special permit only, and shall meet the requirements of Table C-1 for Backlight, Table C-2 for Uplight, and Table C-3 for Glare, without the need for external field-added modifications.

**PRESCRIPTIVE METHOD (cont.) - User's Guide**


**IV. NON-RESIDENTIAL LIGHTING (cont.) - Ordinance Text**

**LIMITS TO OFFSITE IMPACTS**

A seemingly non-compliant fixture, such as a post-top translucent acorn luminaire, may in certain cases meet the BUG ratings, as long as it has proper interior baffling within the acorn globe. However, the BUG ratings in Table C will limit the use of the following types of luminaires in all lighting zones:



**Barn Lights**



**Non-Shielded  
Wall Packs**



**Floodlights or  
lights not aimed  
downward**

**PERFORMANCE METHOD - User's Guide**

**IV. NON-RESIDENTIAL LIGHTING (cont.) - Ordinance Text**

The performance method is best for projects with complex lighting requirements or when the applicant wants or needs more flexibility in lighting design. The performance method is also used when any lighting designer plans to aim or direct any light fixture upward (above 90 degrees). An engineer or lighting professional generally will be required to design within the performance method. An adopting jurisdiction may also wish to hire an engineer or lighting professional to review and approve projects using this method and/or incorporate review of the performance method into special review procedures.

***B. Performance Method***

**1. Total Site Lumen Limit**

The total installed initial luminaire lumens of all lighting systems on the site shall not exceed the allowed total initial site lumens. The allowed total initial site lumens shall be determined using Tables D and E. For sites with existing lighting, existing lighting shall be included in the calculation of total installed lumens.

The total installed initial luminaire lumens of all is calculated as the sum of the initial luminaire lumens for all luminaires.

The Performance Method is also best for projects where higher lighting levels are required compared to typical area lighting. An example might be a car sales lot where more light might be required on the new cars than would be needed for a standard parking lot. Another example is a gas station canopy requiring more light than a building entrance canopy.

The first step in the Performance Method regulates overlighting by establishing the Total Initial Site Lumens (Table D) that are allowed.

Allowances include the summation of the following (Table D):

- 1) Initial lumen allowance per site
- 2) Per area (SF) of hardscape

Table E allows additional lumens for unique site conditions.

Examples of allowances include:

- 1) Per building entrance/exit
- 2) Per length (linear feet) of Outdoor Sales Frontage Perimeter
- 3) Per area (SF) of Vehicle Service Station Canopy
- 4) Plus more ...

The Site Total Initial Site Lumens allowed are a combination of allowances from Table D and Table E.

**IV. NON-RESIDENTIAL LIGHTING (cont.) - User's Guide**

**IV. NON-RESIDENTIAL LIGHTING (cont.) - Ordinance Text**

**LIMITS TO OFFSITE IMPACTS (cont.)**

**PERFORMANCE METHOD**

The second step in the Performance Method is to determine if the proposed luminaires are producing off site impacts such as glare, sky glow and light trespass. One may either use Option A which are the Maximum Allowable BUG Ratings in Table C, or Option B through computer lighting calculations show compliance with Maximum Vertical Illuminance at any point in the plane of the property line in Table F. Option B will be required for all non-residential luminaires that

- A) do not have BUG ratings, or
- B) exceed the BUG ratings,
- C) are not fully shielded, or
- D) have adjustable mountings.

**2. Limits to Off Site Impacts**

All luminaires shall be rated and installed using either Option A or Option B. Only one option may be used per permit application.

For the performance method, Option B (2) requires photometric calculations for the site perimeter, to a height of no less than 33 feet (10 meters) above the tallest luminaire. Vertical illuminances at eye height (5 feet above grade) will give values that can be used to verify compliance by comparing actual site conditions to the photometric plan submitted during review.

Option A: All luminaires shall be rated and installed according to Table C.

Option B: The entire outdoor lighting design shall be analyzed using industry standard lighting software including inter-reflections in the following manner:

Note that the MLO specifies 'total initial luminaire lumens' as a measurement in addition to footcandles/lux. The footcandle is equal to one lumen per square foot. Lux is the metric unit and is equal to one lumen per square meter. 1 footcandle = 10.76 lux, often simplified as 1 footcandle = 10 lux

- 1) Input data shall describe the lighting system including luminaire locations, mounting heights, aiming directions, and employing photometric data tested in accordance with IES guidelines. Buildings or other physical objects on the site within three object heights of the property line must be included in the calculations.
- 2) Reflectances of ground surfaces and physical object surfaces shall be modeled with known or approximated values, but shall be no less than 7%.
- 3) Analysis shall utilize an enclosure comprising calculation planes with zero reflectance values around the perimeter of the site. The top of the enclosure shall be no less than 33 feet (10 meters) above the tallest luminaire. Calculations shall include total lumens upon the inside surfaces of the box top and vertical sides and maximum vertical illuminance (footcandles and/or lux) on the sides of the enclosure.
- 4) The analysis grid on the sides and top of the box shall be adaptive, increasing in density close to maximum orthogonal illuminance points from luminaires. The software shall begin with a 5' (1.5 m) grid in both the horizontal and vertical directions of each plane, to capture the highest points of illuminance on a surface. The grid points begin at 5' (1.5m)

**DESIGN COMPLIANCE - User's Guide**

The application form will require information about the number of luminaires, the number of lamps in each luminaire, the initial luminaire lumens for each luminaire and the initial lumen output for each lamp (based on the wattage and type of lamp selected) as well as plans showing the site area measurements. This will allow the reviewer to verify that the lumen output of all the luminaires does not exceed the allowance.

Field verification can be achieved by asking the applicant and/or owner to verify that the luminaire type, lamp type and wattages specified have been used. Also ask the applicant for photometric data for each luminaire, since the initial luminaire lumens and B-U-G ratings are stated on the photometric report.

However, if a jurisdiction requires additional on-site verification, it may also request a point-by-point photometric plan. While this will not be a true measure of compliance with the criteria of this Ordinance, comparing the actual measured levels on site to the photometric plan can be an indication whether or not the installed lighting varies from the approved design.

**IV. NON-RESIDENTIAL LIGHTING (cont.) - Ordinance Text**

**PERFORMANCE METHOD**

above grade for the vertical planes. Where the orthogonal illuminance values are 50% higher than the average orthogonal illuminance on that surface, the second iteration shall reduce the grid size to 1' (0.3 m) in both cardinal directions to the next point where the illuminance drops to below 50% higher than the average.

The design complies if:

- a) The total lumens on the inside surfaces of the virtual enclosure are less than 15% of the total site lumen limit; and
- b) The maximum vertical illuminance on any vertical surface is less than the allowed maximum illuminance per Table F.

**V. RESIDENTIAL LIGHTING - User's Guide**

This section applies to single family home, duplexes, row houses, and low rise multi-family buildings of 6 dwelling units or less.

**RESIDENTIAL LIGHTING EXCEPTIONS**

The exceptions allow for typical lighting that might exceed the specified limits.

Landscape Lighting - While not common in residential areas, it can cause light pollution and light trespass if it is not controlled.

Lighting controlled by Vacancy (Motion) Sensor - Reduces light pollution and light trespass and should be encouraged.

**RESIDENTIAL LIGHTING EXAMPLE**

In this example on the following page, five different luminaires are used on a residential property. Each luminaire must comply to meet the requirements. The site plan following shows luminaire types followed by a tabulation of each uminaire, whether or not it is fully shielded, lamp type, and initial luminaire lumens. If the luminaire lumens are not known, multiply the initial lamp lumens by the luminaire efficiency. If the efficiency is not known, multiply the initial lamp lumens by 0.7 as a reasonable assumption. The maximum allowable lumen values come from Table G, based on the shielding classification and location on the site. In this case, each luminaire complies with the requirements of Table G.

Comparison of efficacy by power  
(120 Volt Incandescent lamps)

Output (Lumens)	Power (Watt)		
	Incan	CFL	LED
500	40	8 - 10	9
850	60	13 - 18	12 - 15
1,200	75	18 - 22	15
1,700	100	23 - 28	18

**V. RESIDENTIAL LIGHTING - Ordinance Text**

*A. General Requirements*

For residential properties including multiple residential properties not having common areas, all outdoor luminaires shall be fully shielded and shall not exceed the allowed lumen output in Table G, row 2.


*Exceptions*

1. One partly shielded or unshielded luminaire at the main entry, not exceeding the allowed lumen output in Table G row 1.
2. Any other partly shielded or unshielded luminaires not exceeding the allowed lumen output in Table G row 3.
3. Low voltage landscape lighting aimed away from adjacent properties and not exceeding the allowed lumen output in Table G row 4.
4. Shielded directional flood lighting aimed so that direct glare is not visible from adjacent properties and not exceeding the allowed lumen output in Table G row 5.
5. Open flame gas lamps.
6. Lighting installed with a vacancy sensor, where the sensor extinguishes the lights no more than 15 minutes after the area is vacated.
7. Lighting exempt per Section III (B.).

*B. Requirements for Residential Landscape Lighting*

1. Shall comply with Table G.
2. Shall not be aimed onto adjacent properties.

**V. RESIDENTIAL LIGHTING - User's Guide**



Property Type: Residential Lighting Zone 1								
Luminaire Type	Location	Luminaire Description	Fully Shielded	Lamp Type	Initial Luminaire Lumens*	Maximum Allowed Initial Luminaire Lumens (Table G)	Controls	Compliant
A	Front Entry	Decorative wall sconce	No	9W CFL	420	420	None	Yes
B	Garage Door	Fully shielded wall pack	Yes	23W CFL	1050	1260	Occupancy Sensor	Yes
C	Back Entry	Decorative wall sconce	No	7W CFL	280	315	Occupancy Sensor	Yes
D	Shed Entry	Fully shielded wall pack	Yes	40W INC	343	1260	Occupancy Sensor	Yes
E	Driveway	Fully shielded post top	Yes	13W CFL	1260	1260	None	Yes

\*Initial Luminaire Lumens are calculated by multiplying the total initial lamp lumens by the luminaire efficiency. If the luminaire efficiency is not known, assume an efficiency of 70% and multiply the lamp lumens value by 0.7.

**VI. LIGHTING BY SPECIAL PERMIT ONLY - User's Guide**

**VI. LIGHTING BY SPECIAL PERMIT ONLY - Ordinance Text**

This section addresses types of lighting that are intrusive or complex in their impacts and need a higher level of scrutiny and/or site sensitivity.

It should be noted that safety could be compromised if lighting conforming to this ordinance is located adjacent to excessively bright and/or glaring lighting.

It is important that the authority set clear and reasonable guidelines for applying for a special lighting use permit, and establish rules and procedures for granting or refusing them. They may differ from existing special use policies, in which case one or the other may be changed to achieve the overall goal of effective lighting without glare, sky glow, or light trespass.

**SPORTS FIELD LIGHTING**

For athletic and sports fields, the appropriate level of lighting will depend on the Class of Play and Facilities. Class of Play is divided into 4 categories, depending on the number of fixed spectator seats. (Competition play intended for nighttime TV broadcast may require higher lighting levels).

**CLASS I:** Competition play at facilities with 5,000 or more fixed spectator seats. (Professional, Colleges & Universities, some Semi-Professional & Large Sports Cubs)

**CLASS II:** Games at facilities with over 1,500 fixed spectator seats. (Smaller Universities and Colleges, some Semi-pro, large amateur leagues and high schools with large spectator facilities)

**CLASS III:** Games at facilities with over 500 fixed spectator seats. (Sports Clubs and amateur leagues, some high schools and large training professional training facilities with spectator sections)

**CLASS IV:** Competition or recreational play at facilities with 500 fixed spectator seats or less. Class IV Class of Play applies to games at which family and close friends of the players and staff are usually the majority of spectators. (Smaller amateur leagues, park and recreation department facilities, most Little Leagues smaller high schools, elementary and middle schools, and social events)

**A. High Intensity and Special Purpose Lighting**

The following lighting systems are prohibited from being installed or used except by special use permit:

1. Temporary lighting in which any single luminaire exceeds 20,000 initial luminaire lumens or the total lighting load exceeds 160,000 lumens.
2. Aerial Lasers.
3. Searchlights.
4. Other very intense lighting defined as having a light source exceeding 200,000 initial luminaire lumens or an intensity in any direction of more than 2,000,000 candelas.

**B. Complex and Non-Conforming Uses**

Upon special permit issued by the Authority, lighting not complying with the technical requirements of this ordinance but consistent with its intent may be installed for complex sites or uses or special uses including, but not limited to, the following applications:

1. Sports facilities, including but not limited to unconditioned rinks, open courts, fields, and stadiums.
2. Construction lighting.
3. Lighting for industrial sites having special requirements, such as petrochemical manufacturing or storage, shipping piers, etc.
4. Parking structures.
5. Urban parks
6. Ornamental and architectural lighting of bridges, public monuments, statuary and public buildings.
7. Theme and amusement parks.
8. Correctional facilities.

To obtain such a permit, applicants shall demonstrate that the proposed lighting installation:

- a. Has sustained every reasonable effort to mitigate the effects of light on the environment and surrounding properties, supported by a signed statement describing the mitigation measures. Such statement shall be accompanied by the calculations required for the Performance Method.

**SPORTS FIELD LIGHTING**

When Class of Play is above Class IV, a dual control should be installed to limit illumination to Class IV levels during practices where spectators are fewer than 500.

(See IES Recommended Practice for Sports and Recreational Area Lighting RP-6)

**VII. EXISTING LIGHTING - User's Guide**

Adoption of this section on existing lighting is strongly encouraged.

If the adopting jurisdiction has criteria in place that require a property to come into compliance with the current zoning ordinance, it is recommended that the criteria also be applied to bringing existing lighting into compliance. If there are no established criteria, this section of the MLO is recommended.

Amortization allows existing lighting to gradually and gracefully come into compliance. Substantial changes or additions to existing properties are considered the same as new construction, and must comply.

Most outdoor lighting can be fully depreciated once it is fully amortized, usually no longer than 10 years, if not sooner, from the date of initial installation. Some jurisdictions may prefer to require phase-out in a substantially shorter period. The Authority may also wish to require compliance much sooner for "easy fixes" such as re-aiming or lowering lumen output of lamps. Where lighting is judged to be a safety hazard, immediate compliance can be required.

**VI. LIGHTING BY SPECIAL PERMIT ONLY (cont.) - Ordinance Text**

- b. Employs lighting controls to reduce lighting at a Project Specific Curfew ("Curfew") time to be established in the Permit.
- c. Complies with the Performance Method after Curfew.

The Authority shall review each such application. A permit may be granted if, upon review, the Authority believes that the proposed lighting will not create unwarranted glare, sky glow, or light trespass.

**VII. EXISTING LIGHTING - Ordinance Text**

Lighting installed prior to the effective date of this ordinance shall comply with the following.

**A. Amortization**

On or before [amortization date], all outdoor lighting shall comply with this Code.

**B. New Uses or Structures, or Change of Use**

Whenever there is a new use of a property (zoning or variance change) or the use on the property is changed, all outdoor lighting on the property shall be brought into compliance with this Ordinance before the new or changed use commences.

**C. Additions or Alterations**

**1. Major Additions.**

If a major addition occurs on a property, lighting for the entire property shall comply with the requirements of this Code. For purposes of this section, the following are considered to be major additions:

**VII. EXISTING LIGHTING (cont.) - Ordinance Text**

Additions of 25 percent or more in terms of additional dwelling units, gross floor area, seating capacity, or parking spaces, either with a single addition or with cumulative additions after the effective date of this Ordinance.

Single or cumulative additions, modification or replacement of 25 percent or more of installed outdoor lighting luminaires existing as of the effective date of this Ordinance.

**2. Minor Modifications, Additions, or New Lighting Fixtures for Non-residential and Multiple Dwellings**

For non-residential and multiple dwellings, all additions, modifications, or replacement of more than 25 percent of outdoor lighting fixtures existing as of the effective date of this Ordinance shall require the submission of a complete inventory and site plan detailing all existing and any proposed new outdoor lighting.

Any new lighting shall meet the requirements of this Ordinance.

**3. Resumption of Use after Abandonment**

If a property with non-conforming lighting is abandoned for a period of six months or more, then all outdoor lighting shall be brought into compliance with this Ordinance before any further use of the property occurs.

**VIII. ENFORCEMENT & PENALTIES - Ordinance Text**

**(Reserved)**

**VIII. ENFORCEMENT AND PENALTIES - User's Guide**

Enforcement and penalties will vary by jurisdiction. There are, however, certain practices that will promote compliance with lighting regulations. Education is a key tool in promoting compliance. Proactive enforcement procedures can include providing a copy of the lighting regulations to every contractor at the time they visit to obtain a building permit. Another effective tool is a requirement that the builder or developer acknowledge in writing that the he or she is familiar with the lighting requirements and will submit a lighting plan for approval.

**VIII. ENFORCEMENT AND PENALTIES (cont.) - User's Guide**

Submission of the Lighting Plan should be required as a precondition to any approvals. The Lighting Plan should include the location and BUG rating for each luminaire, specify whether compliance is by the performance or prescriptive method, and a worksheet to show that the luminaires and their BUG ratings are compliant.

**IX. TABLES - User's Guide**

The tables are to be reviewed periodically by a joint committee of the IES and IDA, and adjusted as standards and technology permit. If more research on the impacts of outdoor lighting shows the effects of light pollution to be a significant concern, then the values in the tables may be modified. Such changes will have no significant impact to the balance of the language of the Ordinance or Code.

**VIII. ENFORCEMENT & PENALTIES - Ordinance Text**

**IX. TABLES - Ordinance Text**

**Table A - Allowed Total Initial Luminaire Lumens per Site for Non-residential Outdoor Lighting, Per Parking Space Method**

May only be applied to properties up to 10 parking spaces (including handicapped accessible spaces).

LZ-0	LZ-1	LZ-2	LZ-3	LZ-4
350 lms/space	490 lms/space	630 lms/space	840 lms/space	1,050 lms/space

**Table B - Allowed Total Initial Lumens per Site for Non-residential Outdoor Lighting, Hardscape Area Method**

*May be used for any project. When lighting intersections of site drives and public streets or road, a total of 600 square feet for each intersection may be added to the actual site hardscape area to provide for intersection lighting.*

**IX. TABLES - Ordinance Text**

**Table B - Allowed Lumens per SF**

	LZ 0	LZ 1	LZ 2	LZ 3	LZ 4
<b>Base Allowance of lumens per SF of Hardscape</b>	0.5	1.25	2.5	5.0	7.5
<b>Additional allowances for sales and service facilities. No more than two additional allowances per site, Use it or Lose it.</b>					
<b>Outdoor Sales Lots.</b> This allowance is lumens per square foot of uncovered sales lots used exclusively for the display of vehicles or other merchandise for sale, and may not include driveways, parking or other non sales areas. To use this allowance, luminaires must be within 2 mounting heights of sales lot area.	0	4 lumens per square foot	8 lumens per square foot	16 lumens per square foot	16 lumens per square foot
<b>Outdoor Sales Frontage.</b> This allowance is for lineal feet of sales frontage immediately adjacent to the principal viewing location(s) and unobstructed for its viewing length. A corner sales lot may include two adjacent sides provided that a different principal viewing location exists for each side. In order to use this allowance, luminaires must be located between the principal viewing location and the frontage outdoor sales area	0	0	1,000 per LF	1,500 per LF	2,000 per LF
<b>Drive Up Windows.</b> In order to use this allowance, luminaires must be within 20 feet horizontal distance of the center of the window.	0	2,000 lumens per drive-up window	4,000 lumens per drive-up window	8,000 lumens per drive-up window	8,000 lumens per drive-up window
<b>Vehicle Service Station.</b> This allowance is lumens per installed fuel pump.	0	4,000 lumens per pump (based on 5 fc horiz)	8,000 lumens per pump (based on 10 fc horiz)	16,000 lumens per pump (based on 20 fc horiz)	24,000 lumens per pump (based on 20 fc horiz)

**IX. TABLES - TABLE C BUG RATING - User's Guide**

Work on the BUG system started in 2005 when the IES upgraded the roadway cutoff classification system. The original system, which included the ratings full cutoff, cutoff, semi-cutoff and non cutoff, had been designed as a rating system focused on brightness and glare control. However, with increasing demand for control of uplight and light trespass in addition to glare, IES realized that a more comprehensive system was needed. IES developed *TM-15 Luminaire Classification System for Outdoor Luminaires*.

As this is a relatively new rating system, and many people may not be familiar with it, more explanation of how the rating system works is provided here. For example, some people are familiar with terms such as "full cutoff" and they may expect the MLO to include those terms. It will be very important that all groups recognize that older terms and concepts are inadequate for the complex tasks of controlling light pollution. It is recommended that the new rating system adopted in TM-15, as followed herein by the MLO, be used intact and exclusively.

BUG requires downlight only with low glare (better than full cut off) in lighting zones 0, 1 and 2, but allows a minor amount of uplight in lighting zones 3 and 4. In lighting zones 3 and 4, the amount of allowed uplight is enough to permit the use of very well shielded luminaires that have a decorative drop lens or chimney so that dark sky friendly lighting can be installed in places that traditional-appearing luminaires are required. BUG typically cannot be used for residential luminaires unless they have been photometrically tested. For non-photometrically tested residential luminaires, shielding description is used instead.

The lumen limits established for each lighting zone apply to all types of lighting within that zone. This includes, but is not limited to, specialty lighting, façade lighting, security lighting and the front row lighting for auto dealerships. BUG rating limits are defined for each luminaire and

**IX. TABLES (cont.) - Ordinance Text**

**Table C - Maximum Allowable Backlight, Uplight and Glare (BUG) Ratings**

May be used for any project. A luminaire may be used if it is rated for the lighting zone of the site or lower in number for all ratings B, U and G. Luminaires equipped with adjustable mounting devices permitting alteration of luminaire aiming in the field shall not be permitted.

<b>TABLE C-1</b>	<b>Lighting Zone 0</b>	<b>Lighting Zone 1</b>	<b>Lighting Zone 2</b>	<b>Lighting Zone 3</b>	<b>Lighting Zone 4</b>
<b>Allowed Backlight Rating*</b>					
<b>Greater than 2 mounting heights from property line</b>	<b>B4</b>	<b>B4</b>	<b>B4</b>	<b>B5</b>	<b>B5</b>
<b>1 to less than 2 mounting heights from property line and properly oriented**</b>	<b>B1</b>	<b>B2</b>	<b>B3</b>	<b>B4</b>	<b>B4</b>
<b>0.5 to 1 mounting heights from property line and properly oriented**</b>	<b>B0</b>	<b>B1</b>	<b>B2</b>	<b>B3</b>	<b>B3</b>
<b>Less than 0.5 mounting height to property line and properly oriented**</b>	<b>B0</b>	<b>B0</b>	<b>B0</b>	<b>B1</b>	<b>B2</b>

\*For property lines that abut public walkways, bikeways, plazas, and parking lots, the property line may be considered to be 5 feet beyond the actual property line for purpose of determining compliance with this section. For property lines that abut public roadways and public transit corridors, the property line may be considered to be the center-line of the public roadway or public transit corridor for the purpose of determining compliance with this section. NOTE: This adjustment is relative to Table C-1 and C-3 only and shall not be used to increase the lighting area of the site.

\*\* To be considered 'properly oriented', the luminaire must be mounted with the backlight portion of the light output oriented perpendicular and towards the property line of concern.

**IX. TABLES - TABLE C BUG RATING (cont.) - User's Guide**

are based on the internal and external design of the luminaire, its aiming, and the initial luminaire lumens of the specified luminaires. The BUG rating limits also take into consideration the distance the luminaire is installed from the property line in multiples of the mounting height (See Table C).


The three components of BUG ratings are based on IES TM-15-07 (revised):

**Backlight**, which creates light trespass onto adjacent sites. The B rating takes into account the amount of light in the BL, BM, BH, and BVH zones, which are in the direction of the luminaire OPPOSITE from the area intended to be lighted.

**Uplight**, which causes artificial sky glow. Lower uplight (zone UL) causes the most sky glow and negatively affects professional and academic astronomy. Upper uplight (UH) not reflected off a surface is mostly energy waste. The U rating defines the amount of light into the upper hemisphere with greater concern for the light at or near the horizontal angles (UL).

**Glare**, which can be annoying or visually disabling. The G rating takes into account the amount of frontlight in the FH and FVH zones as well as BH and BVH zones.

BUG ratings apply to the Lighting Zone of the property under consideration.



**IX. TABLES (cont.) - Ordinance Text**

**IX. TABLES - TABLE C BUG RATING (cont.) - User's Guide**

(Key: UH=Uplight High, UL=Uplight Low, BVH=Backlight Very High, BH=Backlight High, BM=Backlight Medium, BL=Backlight Low, FVH=Forward Light Very High, FH=Forward Light High, FM=Forward Light Medium, FL=Forward Light Low.)

In general, a higher BUG rating means more light is allowed in solid angles, and the rating increases with the lighting zone. However, a higher B (backlight) rating simply indicates that the luminaire directs a significant portion of light behind the pole, so B ratings are designated based on the location of the luminaire with respect to the property line. A high B rating luminaire maximizes the spread of light, and is effective and efficient when used far from the property line. When luminaires are located near the property line, a lower B rating will prevent unwanted light from interfering with neighboring properties.

At the 90-180 degree ranges:

- Zone 0 allows no light above 90 degrees.
- Zone 1 allows only 10 lumens in the UH and UL zones, 20 lumens total in the complete upper hemisphere. (This is roughly equivalent to a 5 W incandescent lamp).
- Zone 2 allows only 50 lumens in the UH and UL zones, 100 lumens total (less than a 25W incandescent lamp).
- Zone 3 allows only 500 lumens in the UH and UL zones, 1000 lumens total (about the output of a 75W incandescent bulb).
- Zone 4 allows only 1,000 lumens in the UH and UL zones, 2000 lumens total (about the output of a 100W incandescent bulb).

**IX. TABLES (cont.) - Ordinance Text**

**Table C - 2 Maximum Allowable Uplight (BUG) Ratings - Continued**

<b>TABLE C-2</b>	Lighting Zone 0	Lighting Zone 1	Lighting Zone 2	Lighting Zone 3	Lighting Zone 4
Allowed Uplight Rating for Street or Area Lighting	U0	U0	U0	U0	U0
Allowed Uplight Rating for ornamental parking lighting and luminaires not used for street or area lighting	U0	U1	U2	U3	U4

**Table C - 3 Maximum Allowable Glare (BUG) Ratings - Continued**

<b>TABLE C-3</b>	Lighting Zone 0	Lighting Zone 1	Lighting Zone 2	Lighting Zone 3	Lighting Zone 4
Allowed Glare Rating	G0	G1	G2	G3	G4
Any luminaire not ideally oriented <sup>1</sup> with 1 to less than 2 mounting heights to any property line of concern	G0	G0	G1	G1	G2
Any luminaire not ideally oriented <sup>1</sup> with 0.5 to 1 mounting heights to any property line of concern	G0	G0	G0	G1	G1
Any luminaire not ideally oriented <sup>1</sup> with less than 0.5 mounting heights to any property line of concern	G0	G0	G0	G0	G1

<sup>1</sup> If the luminaire is not optically symmetric and the nearest property line is less than 2 mounting heights from the front hemisphere of the luminaire distribution, the reduced glare rating must be met.

**TABLE D EXAMPLE - PERFORMANCE METHOD - User's Guide**

The first step in the Performance Method is to establish the Site Total Initial Site Lumens which regulates overlighting. The performance method allows layers of light depending on the complexity of the site.

Table D establishes the basic total initial site lumens allowed. These lumen allowances are added together for a total initial site lumen allowance. Allowances include:

- 1) Initial lumen allowance per site
- 2) Per area (SF) of hardscape

**IX. TABLES (cont.) - Ordinance Text**

**Table D Performance Method Allowed Total Initial Site Lumens**

*May be used on any project.*

Lighting Zone	LZ 0	LZ 1	LZ 2	LZ 3	LZ 4
Allowed Lumens Per SF	0.5	1.25	2.5	5.0	7.5
Allowed Base Lumens Per Site	0	3,500	7,000	14,000	21,000

**Table E Performance Method Additional Initial Luminaire Lumen Allowances. All of the following are “use it or lose it” allowances.**

All area and distance measurements in plan view unless otherwise noted.

Lighting Application	LZ 0	LZ 1	LZ 2	LZ 3	LZ 4
<b>Additional Lumens Allowances for All Buildings except service stations and outdoor sales facilities. A MAXIMUM OF THREE (3) ALLOWANCES ARE PERMITTED. THESE ALLOWANCES ARE “USE IT OR LOSE IT”.</b>					
<b>Building Entrances or Exits.</b> This allowance is per door. In order to use this allowance, luminaires must be within 20 feet of the door.	400	1,000	2,000	4,000	6,000
<b>Building Facades.</b> This allowance is lumens per unit area of building façade that are illuminated. To use this allowance, luminaires must be aimed at the façade and capable of illuminating it without obstruction.	0	0	8/SF	16/SF	24/SF

**TABLE E PERFORMANCE METHOD - User's Guide**

The allowable light levels for these uses defined in Table E may be used to set a prescriptive lighting allowance for these uses in each lighting zone. It should be noted that the lighting allowance defined in Table E is only applicable for the area defined for that use and cannot be transferred to another area of the site. For some uses, such as outdoor sales, the jurisdiction is encouraged to define a percentage of the total hardscape area that is eligible for the additional lighting allowance. For example, a set percentage of a car dealership's lot may be considered a display area and receive the additional lighting allowance where the remainder of the lot would be considered storage, visitor parking, etc. and cannot exceed the base light levels defined in Table A.

**TABLE E EXAMPLE - PERFORMANCE METHOD - User's Guide**

**IX. TABLES (cont.) - Ordinance Text**

**Table E - Performance Method Additional Initial Lumen Allowances (cont.)**

Lighting Application	LZ 0	LZ 1	LZ 2	LZ 3	LZ 4
<b>Sales or Non-sales Canopies.</b> This allowance is lumens per unit area for the total area within the drip line of the canopy. In order to qualify for this allowance, luminaires must be located under the canopy.	0	3/SF	6/SF	12/SF	18/SF
<b>Guard Stations.</b> This allowance is lumens per unit area of guardhouse plus 2000 sf per vehicle lane. In order to use this allowance, luminaires must be within 2 mounting heights of a vehicle lane or the guardhouse.	0	6/SF	12/SF	24/SF	36/SF
<b>Outdoor Dining.</b> This allowance is lumens per unit area for the total illuminated hardscape of outdoor dining. In order to use this allowance, luminaires must be within 2 mounting heights of the hardscape area of outdoor dining	0	1/SF	5/SF	10/SF	15/SF
<b>Drive Up Windows.</b> This allowance is lumens per window. In order to use this allowance, luminaires must be within 20 feet of the center of the window.	0	2,000 lumens per drive-up window	4,000 lumens per drive-up window	8,000 lumens per drive-up window	8,000 lumens per drive-up window
<b>Additional Lumens Allowances for Service Stations only. Service stations may not use any other additional allowances.</b>					
<b>Vehicle Service Station Hardscape.</b> This allowance is lumens per unit area for the total illuminated hardscape area less area of buildings, area under canopies, area off property, or areas obstructed by signs or structures. In order to use this allowance, luminaires must be illuminating the hardscape area and must not be within a building, below a canopy, beyond property lines, or obstructed by a sign or other structure.	0	4/SF	8/SF	16/SF	24/SF

**IX. TABLES (cont.) - Ordinance Text**

**Table E - Performance Method Additional Initial Lumen Allowances (cont.)**

<b>Lighting Application</b>	<b>LZ 0</b>	<b>LZ 1</b>	<b>LZ 2</b>	<b>LZ 3</b>	<b>LZ 4</b>
<p><b>Vehicle Service Station Canopies.</b> This allowance is lumens per unit area for the total area within the drip line of the canopy. In order to use this allowance, luminaires must be located under the canopy.</p>	<b>0</b>	<b>8/SF</b>	<b>16/SF</b>	<b>32/SF</b>	<b>32/SF</b>
<p><b>Additional Lumens Allowances for Outdoor Sales facilities only.</b>                      Outdoor Sales facilities may not use any other additional allowances.  <b>NOTICE:</b> lighting permitted by these allowances shall employ controls extinguishing this lighting after a curfew time to be determined by the Authority.</p>					
<p><b>Outdoor Sales Lots.</b> This allowance is lumens per square foot of uncovered sales lots used exclusively for the display of vehicles or other merchandise for sale, and may not include driveways, parking or other non sales areas and shall not exceed 25% of the total hardscape area. To use this allowance, Luminaires must be within 2 mounting heights of the sales lot area.</p>	<b>0</b>	<b>4/SF</b>	<b>8/SF</b>	<b>12/SF</b>	<b>18/SF</b>
<p><b>Outdoor Sales Frontage.</b> This allowance is for lineal feet of sales frontage immediately adjacent to the principal viewing location(s) and unobstructed for its viewing length. A corner sales lot may include two adjacent sides provided that a different principal viewing location exists for each side. In order to use this allowance, luminaires must be located between the principal viewing location and the frontage outdoor sales area.</p>	<b>0</b>	<b>0</b>	<b>1,000/LF</b>	<b>1,500/LF</b>	<b>2,000/LF</b>

**IX. TABLES (cont.) - Ordinance Text**

**Table F Maximum Vertical Illuminance at any point in the plane of the property line**

<b>Lighting Zone 0</b>	<b>Lighting Zone 1</b>	<b>Lighting Zone 2</b>	<b>Lighting Zone 3</b>	<b>Lighting Zone 4</b>
<b>0.05 FC or 0.5 LUX</b>	<b>0.25 FC or 2.5 LUX</b>	<b>0.5 FC or 5.0 LUX</b>	<b>1.0 FC or 10.0 LUX</b>	<b>2.5 FC or 25.0 LUX</b>

**IX. TABLES (cont.) - Ordinance Text**

**Table G - Residential Lighting Limits**

Lighting Application	LZ 0	LZ 1	LZ 2	LZ 3	LZ 4
<b>Row 1</b> Maximum Allowed Luminaire Lumens* for Unshielded Luminaires at one entry only	Not allowed	420 lumens	630 lumens	630 lumens	630 lumens
<b>Row 2</b> Maximum Allowed Luminaire Lumens* for each Fully Shielded Luminaire	630 lumens	1,260 lumens	1,260 lumens	1,260 lumens	1,260 lumens
<b>Row 3</b> Maximum Allowed Luminaire Lumens* for each Unshielded Luminaire excluding main entry	Not allowed	315 lumens	315 lumens	315 lumens	315 lumens
<b>Row 4</b> Maximum Allowed Luminaire Lumens* for each Landscape Lighting	Not allowed	Not allowed	1,050 lumens	2,100 lumens	2,100 lumens
<b>Row 5</b> Maximum Allowed Luminaire Lumens* for each Shielded Directional Flood Lighting	Not allowed	Not allowed	1,260 lumens	2,100 lumens	2,100 lumens
<b>Row 6</b> Maximum Allowed Luminaire Lumens* for each Low Voltage Landscape Lighting	Not allowed	Not allowed	525 lumens	525 lumens	525 lumens

\* Luminaire lumens equals Initial Lamp Lumens for a lamp, multiplied by the number of lamps in the luminaire

**TABLE G RESIDENTIAL LIGHTING - User's Guide**

**Residential Light Levels**

Most residential lighting has traditionally used incandescent lamps which are identified by their wattage. However, since new technologies provide more light for fewer watts, it is no longer possible to regulate residential lighting solely by providing a maximum wattage. Table G, therefore, lists maximum initial luminaire lumens only.

**X. DEFINITIONS - User's Guide**


Definitions are typically generally added to any code when new code sections are added. The definitions are legally required and play a significant role in the interpretation of the ordinance and code.

Most city attorneys will not accept references to outside sources regardless of credibility, such as the IES Handbook. Thus as a general rule, a definition for an unfamiliar term (e.g. lumens) must be added by the adopting ordinance.

When adopting or integrating the MLO definitions, be sure to retire conflicting technical terminology. In particular, the latest IES Luminaire Classification System as defined in IES TM-15-07 is likely to need attention.

**X. DEFINITIONS - Ordinance Text**

<i><b>Absolute Photometry</b></i>	Photometric measurements (usually of a solid-state luminaire) that directly measures the footprint of the luminaire. Reference Standard IES LM-79
<i><b>Architectural Lighting</b></i>	Lighting designed to reveal architectural beauty, shape and/or form and for which lighting for any other purpose is incidental.
<i><b>Authority</b></i>	The adopting municipality, agency or other governing body.
<i><b>Astronomic Time Switch</b></i>	An automatic lighting control device that switches outdoor lighting relative to time of solar day with time of year correction.
<i><b>Backlight</b></i>	For an exterior luminaire, lumens emitted in the quarter sphere below horizontal and in the opposite direction of the intended orientation of the luminaire. For luminaires with symmetric distribution, backlight will be the same as front light.
<i><b>BUG</b></i>	A luminaire classification system that classifies backlight (B), uplight (U) and glare (G).
<i><b>Canopy</b></i>	A covered, unconditioned structure with at least one side open for pedestrian and/or vehicular access. (An unconditioned structure is one that may be open to the elements and has no heat or air conditioning.)
<i><b>Common Outdoor Areas</b></i>	One or more of the following: a parking lot; a parking structure or covered vehicular entrance; a common entrance or public space shared by all occupants of the domiciles.
<i><b>Curfew</b></i>	A time defined by the authority when outdoor lighting is reduced or extinguished.



**X. DEFINITIONS - Ordinance Text**

<p><b><i>Emergency conditions</i></b></p>	<p>Generally, lighting that is only energized during an emergency; lighting fed from a backup power source; or lighting for illuminating the path of egress solely during a fire or other emergency situation; or, lighting for security purposes used solely during an alarm.</p>
<p><b><i>Footcandle</i></b></p>	<p>The unit of measure expressing the quantity of light received on a surface. One footcandle is the illuminance produced by a candle on a surface one foot square from a distance of one foot.</p>
<p><b><i>Forward Light</i></b></p>	<p>For an exterior luminaire, lumens emitted in the quarter sphere below horizontal and in the direction of the intended orientation of the luminaire.</p>
<p><b><i>Fully Shielded Luminaire</i></b></p>	<p>A luminaire constructed and installed in such a manner that all light emitted by the luminaire, either directly from the lamp or a diffusing element, or indirectly by reflection or refraction from any part of the luminaire, is projected below the horizontal plane through the luminaire's lowest light-emitting part.</p>
<p><b><i>Glare</i></b></p>	<p>Lighting entering the eye directly from luminaires or indirectly from reflective surfaces that causes visual discomfort or reduced visibility.</p>
<p><b><i>Hardscape</i></b></p>	<p>Permanent hardscape improvements to the site including parking lots, drives, entrances, curbs, ramps, stairs, steps, medians, walkways and non-vegetated landscaping that is 10 feet or less in width. Materials may include concrete, asphalt, stone, gravel, etc.</p>
<p><b><i>Hardscape Area</i></b></p>	<p>The area measured in square feet of all hardscape. It is used to calculate the Total Site Lumen Limit in both the Prescriptive Method and Performance Methods. Refer to Hardscape definition.</p>

**X. DEFINITIONS - Ordinance Text**

<b><i>Hardscape Perimeter</i></b>	The perimeter measured in linear feet is used to calculate the Total Site Lumen Limit in the Performance Method. Refer to Hardscape definition.
<b><i>IDA</i></b>	International Dark-Sky Association.
<b><i>IESNA</i></b>	Illuminating Engineering Society of North America.
<b><i>Impervious Material</i></b>	Sealed to severely restrict water entry and movement
<b><i>Industry Standard Lighting Software</i></b>	Lighting software that calculates point-by-point illuminance that includes reflected light using either ray-tracing or radiosity methods.
<b><i>Lamp</i></b>	A generic term for a source of optical radiation (i.e. “light”), often called a “bulb” or “tube”. Examples include incandescent, fluorescent, high-intensity discharge (HID) lamps, and low pressure sodium (LPS) lamps, as well as light-emitting diode (LED) modules and arrays.
<b><i>Landscape Lighting</i></b>	Lighting of trees, shrubs, or other plant material as well as ponds and other landscape features.
<b><i>LED</i></b>	Light Emitting Diode.
<b><i>Light Pollution</i></b>	Any adverse effect of artificial light including, but not limited to, glare, light trespass, sky-glow, energy waste, compromised safety and security, and impacts on the nocturnal environment.

**X. DEFINITIONS - Ordinance Text**

<b><i>Light Trespass</i></b>	Light that falls beyond the property it is intended to illuminate.
<b><i>Lighting</i></b>	“Electric” or “man-made” or “artificial” lighting. See “lighting equipment”.
<b><i>Lighting Equipment</i></b>	Equipment specifically intended to provide gas or electric illumination, including but not limited to, lamp(s), luminaire(s), ballast(s), poles, posts, lens(s), and related structures, electrical wiring, and other necessary or auxiliary components.
<b><i>Lighting Zone</i></b>	An overlay zoning system establishing legal limits for lighting for particular parcels, areas, or districts in a community.
<b><i>Lighting Equipment</i></b>	Equipment specifically intended to provide gas or electric illumination, including but not limited to, lamp(s), luminaire(s), ballast(s), poles, posts, lens(s), and related structures, electrical wiring, and other necessary or auxiliary components.
<b><i>Low Voltage Landscape Lighting</i></b>	Landscape lighting powered at less than 15 volts and limited to luminaires having a rated initial luminaire lumen output of 525 lumens or less.
<b><i>Lumen</i></b>	The unit of measure used to quantify the amount of light produced by a lamp or emitted from a luminaire (as distinct from “watt,” a measure of power consumption).
<b><i>Luminaire</i></b>	The complete lighting unit (fixture), consisting of a lamp, or lamps and ballast(s) (when applicable), together with the parts designed to distribute the light (reflector, lens, diffuser), to position and protect the lamps, and to connect the lamps to the power supply.

**X. DEFINITIONS - Ordinance Text**

**Mounting Height:** The horizontal spacing of poles is often measured in units of “mounting height”. Example: “The luminaires can be spaced up to 4 mounting heights apart.”

<b><i>Luminaire Lumens</i></b>	For luminaires with relative photometry per IES, it is calculated as the sum of the initial lamp lumens for all lamps within an individual luminaire, multiplied by the luminaire efficiency. If the efficiency is not known for a residential luminaire, assume 70%. For luminaires with absolute photometry per IES LM-79, it is the total luminaire lumens. The lumen rating of a luminaire assumes the lamp or luminaire is new and has not depreciated in light output.
<b><i>Lux</i></b>	The SI unit of illuminance. One lux is one lumen per square meter. 1 Lux is a unit of incident illuminance approximately equal to 1/10 footcandle.
<b><i>Mounting height</i></b>	The height of the photometric center of a luminaire above grade level.
<b><i>New lighting</i></b>	Lighting for areas not previously illuminated; newly installed lighting of any type except for replacement lighting or lighting repairs.
<b><i>Object</i></b>	A permanent structure located on a site. Objects may include statues or artwork, garages or canopies, outbuildings, etc.
<b><i>Object Height</i></b>	The highest point of an entity, but shall not include antennas or similar structures.
<b><i>Ornamental lighting</i></b>	Lighting that does not impact the function and safety of an area but is purely decorative, or used to illuminate architecture and/or landscaping, and installed for aesthetic effect.

**X. DEFINITIONS - Ordinance Text**

<p><b><i>Ornamental Street Lighting</i></b></p>	<p>A luminaire intended for illuminating streets that serves a decorative function in addition to providing optics that effectively deliver street lighting. It has a historical period appearance or decorative appearance, and has the following design characteristics:</p> <ul style="list-style-type: none"> <li>· designed to mount on a pole using an arm, pendant, or vertical tenon;</li> <li>· opaque or translucent top and/or sides;</li> <li>· an optical aperture that is either open or enclosed with a flat, sag or drop lens;</li> <li>· mounted in a fixed position; and</li> <li>· with its photometric output measured using Type C photometry per IESNA LM-75-01.</li> </ul>
<p><b><i>Outdoor Lighting</i></b></p>	<p>Lighting equipment installed within the property line and outside the building envelopes, whether attached to poles, building structures, the earth, or any other location; and any associated lighting control equipment.</p>
<p><b><i>Partly shielded luminaire</i></b></p>	<p>A luminaire with opaque top and translucent or perforated sides, designed to emit most light downward.</p>
<p><b><i>Pedestrian Hardscape</i></b></p>	<p>Stone, brick, concrete, asphalt or other similar finished surfaces intended primarily for walking, such as sidewalks and pathways.</p>
<p><b><i>Photoelectric Switch</i></b></p>	<p>A control device employing a photocell or photodiode to detect daylight and automatically switch lights off when sufficient daylight is available.</p>
<p><b><i>Properly Oriented</i></b></p>	<p>To be considered 'properly oriented', a luminaire must be mounted with the backlight portion of the light output oriented perpendicular and towards the property line of concern.</p>

**X. DEFINITIONS - Ordinance Text**

<i>Property line</i>	The edges of the legally-defined extent of privately owned property.
<i>Relative photometry</i>	Photometric measurements made of the lamp plus luminaire, and adjusted to allow for light loss due to reflection or absorption within the luminaire. Reference standard: IES LM-63.
<i>Repair(s)</i>	The reconstruction or renewal of any part of an existing luminaire for the purpose of its on-going operation, other than relamping or replacement of components including capacitor, ballast or photocell. Note that retrofitting a luminaire with new lamp and/or ballast technology is not considered a repair and for the purposes of this ordinance the luminaire shall be treated as if new. "Repair" does <b>not</b> include normal relamping or replacement of components including capacitor, ballast or photocell.
<i>Replacement Lighting</i>	Lighting installed specifically to replace existing lighting that is sufficiently broken to be beyond repair.
<i>Sales area</i>	Uncovered area used for sales of retail goods and materials, including but not limited to automobiles, boats, tractors and other farm equipment, building supplies, and gardening and nursery products.
<i>Seasonal lighting</i>	Temporary lighting installed and operated in connection with holidays or traditions.
<i>Shielded Directional Luminaire</i>	A luminaire that includes an adjustable mounting device allowing aiming in any direction and contains a shield, louver, or baffle to reduce direct view of the lamp.
<i>Sign</i>	Advertising, directional or other outdoor promotional display of art, words and/or pictures.

**X. DEFINITIONS - Ordinance Text**

<i><b>Sky Glow</b></i>	The brightening of the nighttime sky that results from scattering and reflection of artificial light by moisture and dust particles in the atmosphere. Skyglow is caused by light directed or reflected upwards or sideways and reduces one's ability to view the night sky.
<i><b>Temporary lighting</b></i>	Lighting installed and operated for periods not to exceed 60 days, completely removed and not operated again for at least 30 days.
<i><b>Third Party</b></i>	A party contracted to provide lighting, such as a utility company.
<i><b>Time Switch</b></i>	An automatic lighting control device that switches lights according to time of day.
<i><b>Translucent</b></i>	Allowing light to pass through, diffusing it so that objects beyond cannot be seen clearly (not transparent or clear).
<i><b>Unshielded Luminaire</b></i>	A luminaire capable of emitting light in any direction including downwards.
<i><b>Uplight</b></i>	For an exterior luminaire, flux radiated in the hemisphere at or above the horizontal plane.
<i><b>Vertical Illuminance</b></i>	Illuminance measured or calculated in a plane perpendicular to the site boundary or property line.

**XI. OPTIONAL STREETLIGHT ORDINANCE - User's Guide**

This section was added since the first public review. It is designed to work closely with the proposed revision to ANSI/IES RP-8 Standard Practice for Roadway and Street Lighting.

Street and roadway lighting is one of the world's largest causes of artificial skyglow. Many adopting agencies will recognize that the MLO will make privately owned lighting more efficient and environmentally responsible than their street lighting systems. But because the process of designing street lighting often requires more precise lighting calculations, applying the MLO directly to street lighting is not advised. Using existing standards of street lighting is recommended, particularly IES RP-8 and AASHTO standards.

Until a new recommended practice for street lighting can be developed, this section can serve to prevent most of the uplight of street lighting systems without setting specific requirements for the amount of light, uniformity of light, or other performance factors. Adopting agencies should include these basic improvements to street lighting along with regulations to private lighting.

Lighting streets with "period" ornamental luminaires that evoke the look of a time when the light source was a gas flame can cause glare if high-lumen lamps are used. Such ornamental street lights should not exceed a BUG rating of G1. If additional illuminance and/or uniformity is desired, the ornamental fixtures should be supplemented by higher mounted fully shielded luminaires, as illustrated in RP-33-99.

Few street lighting warranting processes exist. The adopting agency needs to gauge whether a complex warranting systems is required, or if a simple one using posted speeds, presence of pedestrians, or other practical considerations is sufficient.

Examples of a current street lighting warranting system are included in the Transportation Association of Canada's Guide for the Design of Roadway Lighting 2006.

**XI. OPTIONAL STREETLIGHT ORDINANCE - Ordinance Text**

***Note to the adopting authority: the intent of this section is that it only applies to streets and not to roadways or highways.***

***A. Preamble***

The purpose of this Ordinance is to control the light pollution of street lighting, including all collectors, local streets, alleys, sidewalks and bike-ways, as defined by ANSI/IES RP-8 Standard Practice for Roadway and Street Lighting and in a manner consistent with the Model Lighting Ordinance.

***B. Definitions***

Roadway or Highway lighting is defined as lighting provided for freeways, expressways, limited access roadways, and roads on which pedestrians, cyclists, and parked vehicles are generally not present. The primary purpose of roadway or highway lighting is to help the motorist remain on the roadway and help with the detection of obstacles within and beyond the range of the vehicle's headlights.

Street lighting is defined as lighting provided for major, collector, and local roads where pedestrians and cyclists are generally present. The primary purpose of street lighting is to help the motorist identify obstacles, provide adequate visibility of pedestrians and cyclists, and assist in visual search tasks, both on and adjacent to the roadway.

Ornamental Street Lighting is defined as a luminaire intended for illuminating streets that serves a decorative function in addition to providing optics that effectively deliver street lighting. It has a historical period appearance or decorative appearance, and has the following design characteristics:

- designed to mount on a pole using an arm, pendant, or vertical tenon;
- opaque or translucent top and/or sides;
- an optical aperture that is either open or enclosed with a flat, sag or drop lens;
- mounted in a fixed position; and
- with its photometric output measured using Type C photometry per IESNA LM-75-01.

**XI. OPTIONAL STREETLIGHT ORDINANCE - Ordinance Text*****C. Scope***

All street lighting not governed by regulations of federal, state or other superseding jurisdiction.

***EXCEPTION:*** lighting systems mounted less than 10.5 feet above street level and having less than 1000 initial lumens each.

***D. Master Lighting Plan***

The Authority shall develop a Master Lighting Plan based on the American Association of State Highway and Transportation Officials (AASHTO) Roadway Lighting Design Guide GL-6, October 2005, Chapter 2. Such plan shall include, but not be limited to, the Adoption of Lighting Zones and:

1. Goals of street lighting in the jurisdiction by Lighting Zone
2. Assessment of the safety and security issues in the jurisdiction by Lighting Zone
3. Environmentally judicious use of resources by Lighting Zone
4. Energy use and efficiency by Lighting Zone
5. Curfews to reduce or extinguish lighting when no longer needed by Lighting Zone

***E. Warranting***

The Authority shall establish a warranting process to determine whether lighting is required. Such warranting process shall not assume the need for any lighting nor for continuous lighting unless conditions warrant the need. Lighting shall only be installed where warranted.

**XI. OPTIONAL STREETLIGHT ORDINANCE - Ordinance Text**

***F. Light Shielding and Distribution***

All street lighting shall have no light emitted above 90 degrees.

Exception: Ornamental street lighting for specific districts or projects shall be permitted by special permit only, and shall meet the requirements of Table H below without the need for external field-added modifications.

**Table H - Uplight Control Requirements for Ornamental Street Lights - by Special Permit Only**

Lighting Zone	Maximum Uplight Rating
LZ-0	U-0
LZ-1	U-1
LZ-2	U-2
LZ-3	U-3
LZ-4	U-4